

**ADDENDUM NO. 1**

Project: 2025 Bridge Deck Replacement

Owner: St. Clair County Transit District

Addendum Date: 9/22/2025

This Addendum is issued to all prospective bidders and shall become part of the Contract Documents. Bidders shall acknowledge receipt of this Addendum on the Bid Form.

**CLARIFICATION**

Reference: Exhibit A, Sheet 3 of 16 — Section Thru Deck and Section C-C.

- The two (2) 2x6 center nailers shown in the referenced drawings are not present on the existing deck structure.
- Requirement: The center nailers shall be installed as shown on Exhibit A, Sheet 3 of 16.
- At the Contractor’s option, the center nailers may be installed using screws from below the deck.
- If screws are installed from below, they shall be #10 x 3½" screws to ensure they do not protrude through the top of the deck.

All other provisions of the Bid Documents remain unchanged.

**ACKNOWLEDGEMENT**

Each Bidder shall acknowledge receipt of this Addendum by affixing their signature below, by noting this Addendum on their Bid Form, and by attaching this Addendum to their Bid. The undersigned acknowledges receipt of this Addendum and the Bid submitted is in accordance with information, instructions, and stipulations set forth herein.

Bidder: \_\_\_\_\_

By: \_\_\_\_\_

Date: \_\_\_\_\_

